

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE  
IN ACCORDANCE WITH EN 13501-1:2018

Classification no.	2025-Efectis-R000675
Sponsor	Gealan Fenster-Systeme GmbH Hoferstrasse 80 D-95145 OBERKOTZAU GERMANY
Product name	Window system with and without Acrycolor
Prepared by	Efectis Nederland BV
Notified body no.	1234
Author(s)	John Hart Job Onderwater
Project number	ENL-24-001178
Date of issue	July 2025
Number of pages	6

#### 4.2 CLASSIFICATION

The product, **window system with and without Acrycolor**, in relation to its reaction to fire behaviour is classified:

**B**

The additional classification in relation to smoke production is:

**s3**

The additional classification in relation to flaming droplets / particles is:

**d0**

**Reaction to fire classification: B – s3, d0**

As a consequence, the manufacturer has concluded that system 3 AVCP is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

03/07/2025



Signed by: John HART

Project leader Reaction to Fire

03/07/2025



Signed by: Job ONDERWATER

Project leader Reaction to Fire